



## STATE-BY-STATE “VGB 2008” EXTRA/SPECIAL DEPARTMENT OF HEALTH (D.O.H.) REQUIREMENTS

STATE	FPS OR GPM	FLAT VS. DOMED	CHANNEL DRAINS	I.C.C. ADOPTION	SPECIAL COUNTY OR REGIONAL
ALABAMA	GPM				
ALASKA	?		?		
ARIZONA	GPM Except Maricopa = 1.5 fps		Pending as a single, unblockable; okay at 2		“Old” 1.5 fps code in Maricopa code is being enforced again.
ARKANSAS	GPM				
CALIFORNIA	GPM		O.K.		*Central & Northern CA O.K. with field fabricated sumps & channel drains. *Long Beach: Pending interpretations. *L.A. county & Southern CA (except for Orange County & San Diego County) require manufactured sumps; 2 pipes to channel drains.
COLORADO	1.5 fps				
CONNECTICUT	1.5 fps				

**\*Notation:**

GPM = Gallons Per Minute maximum per ASME A112 Test (as engraved on cover)

AV = Anti-Vortex

FPS = Cubic Feet Per Second

1.5 fps = 4.7 x square inches opening

1.0 fps = 3.1 x square inches opening

P 877-768-2717 F 877-276-POOL info@aquastarpoolproducts.com www.aquastarpoolproducts.com





## STATE-BY-STATE “VGB 2008” EXTRA/SPECIAL DEPARTMENT OF HEALTH (D.O.H.) REQUIREMENTS

STATE	FPS OR GPM	FLAT VS. DOMED	CHANNEL DRAINS	I.C.C. ADOPTION	SPECIAL COUNTY OR REGIONAL
DELAWARE	GPM				
FLORIDA	1.5 fps!		O.K.		*Approved covers must be listed with STATE, also
GEORGIA	1.5 fps				*Extra concern regarding finger probe tests
HAWAII	GPM		O.K.		
IDAHO	?				
ILLINOIS	1.5 fps				
INDIANA	1.0 fps!				
IOWA	?				

**\*Notation:**

GPM = Gallons Per Minute maximum per ASME A112 Test  
(as engraved on cover)

AV = Anti-Vortex  
FPS = Cubic Feet Per Second

1.5 fps = 4.7 x square inches opening  
1.0 fps = 3.1 x square inches opening

P 877-768-2717 F 877-276-POOL info@aquastarpoolproducts.com www.aquastarpoolproducts.com





## STATE-BY-STATE “VGB 2008” EXTRA/SPECIAL DEPARTMENT OF HEALTH (D.O.H.) REQUIREMENTS

STATE	FPS OR GPM	FLAT VS. DOMED	CHANNEL DRAINS	I.C.C. ADOPTION	SPECIAL COUNTY OR REGIONAL
KANSAS	?				
KENTUCKY	1.5 fps				
MAINE	GPM				
MARYLAND	GPM				
MASSACHUSETTS	2.0 x 1.5				
MICHIGAN	1.0 fps!				
MINNESOTA	1.5 fps				
MISSISSIPPI	GPM				

**\*Notation:**

GPM = Gallons Per Minute maximum per ASME A112 Test  
(as engraved on cover)

AV = Anti-Vortex  
FPS = Cubic Feet Per Second

1.5 fps = 4.7 x square inches opening  
1.0 fps = 3.1 x square inches opening

P 877-768-2717 F 877-276-POOL info@aquastarpoolproducts.com www.aquastarpoolproducts.com





## STATE-BY-STATE “VGB 2008” EXTRA/SPECIAL DEPARTMENT OF HEALTH (D.O.H.) REQUIREMENTS

STATE	FPS OR GPM	FLAT VS. DOMED	CHANNEL DRAINS	I.C.C. ADOPTION	SPECIAL COUNTY OR REGIONAL
MISSOURI	Per Cover GPM				Check with local officials regarding 1.5 fps
MONTANA	GPM				
NEBRASKA	SEE →	1.5 fps for flat 6.0 fps for domed, A.V. style			
NEVADA	1.5 fps				*Special individual approvals for higher fps ratings must be okayed
NEW HAMPSHIRE	1.5 fps				
NEW JERSEY	1.5 fps				
NEW MEXICO	GPM				
NEW YORK	1.5 fps				*Regarding Finger Probe: less than 1/2" 1 dimension

**\*Notation:**

GPM = Gallons Per Minute maximum per ASME A112 Test (as engraved on cover)

AV = Anti-Vortex  
FPS = Cubic Feet Per Second

1.5 fps = 4.7 x square inches opening  
1.0 fps = 3.1 x square inches opening

P 877-768-2717 F 877-276-POOL info@aquastarpoolproducts.com www.aquastarpoolproducts.com





## STATE-BY-STATE “VGB 2008” EXTRA/SPECIAL DEPARTMENT OF HEALTH (D.O.H.) REQUIREMENTS

STATE	FPS OR GPM	FLAT VS. DOMED	CHANNEL DRAINS	I.C.C. ADOPTION	SPECIAL COUNTY OR REGIONAL
NORTH CAROLINA	1.5 fps → & 6.0 fps →	If flat  If domed			
NORTH DAKOTA	GPM				
OHIO	1.5 fps				
OKLAHOMA	1.5 fps				
OREGON	GPM				*Changed “old” code from 1.5 fps to GPM engraving Nov. 2008
PENNSYLVANIA	GPM				
RHODE ISLAND	GPM				
SOUTH CAROLINA	GPM				*Some Counties still require the soon to be obsolete use of the word = “Anti-Vortex” or “AV”.

**\*Notation:**

GPM = Gallons Per Minute maximum per ASME A112 Test  
(as engraved on cover)

AV = Anti-Vortex  
FPS = Cubic Feet Per Second

1.5 fps = 4.7 x square inches opening  
1.0 fps = 3.1 x square inches opening

P 877-768-2717 F 877-276-POOL info@aquastarpoolproducts.com www.aquastarpoolproducts.com





## STATE-BY-STATE “VGB 2008” EXTRA/SPECIAL DEPARTMENT OF HEALTH (D.O.H.) REQUIREMENTS

STATE	FPS OR GPM	FLAT VS. DOMED	CHANNEL DRAINS	I.C.C. ADOPTION	SPECIAL COUNTY OR REGIONAL
SOUTH DAKOTA	?				
TENNESSEE	GPM				
TEXAS	Varies throughout the state. Check with local officials				
UTAH	1.5 fps				
VERMONT	GPM				
VIRGINIA	GPM				
WASHINGTON	1.5 fps				
WEST VIRGINIA	GPM				

**\*Notation:**

GPM = Gallons Per Minute maximum per ASME A112 Test  
(as engraved on cover)

AV = Anti-Vortex  
FPS = Cubic Feet Per Second

1.5 fps = 4.7 x square inches opening  
1.0 fps = 3.1 x square inches opening

P 877-768-2717 F 877-276-POOL info@aquastarpoolproducts.com www.aquastarpoolproducts.com





## STATE-BY-STATE “VGB 2008” EXTRA/SPECIAL DEPARTMENT OF HEALTH (D.O.H.) REQUIREMENTS

STATE	FPS OR GPM	FLAT VS. DOMED	CHANNEL DRAINS	I.C.C. ADOPTION	SPECIAL COUNTY OR REGIONAL
WISCONSIN	1.5 FPS				
WYOMING	GPM				

**\*Notation:**

GPM = Gallons Per Minute maximum per ASME A112 Test  
(as engraved on cover)

AV = Anti-Vortex  
FPS = Cubic Feet Per Second

1.5 fps = 4.7 x square inches opening  
1.0 fps = 3.1 x square inches opening

P 877-768-2717 F 877-276-POOL info@aquastarpoolproducts.com www.aquastarpoolproducts.com

